

Environmental Protection Agency

§ 421.35

NSPS—Continued

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
Oil and grease000	.000
pH	(¹)	(¹)

¹Within the range of 7.0 to 10.0 at all times.

(j) Subpart C—Shot Casting Contact Cooling.

NSPS

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum cast	
Lead000	.000
Zinc000	.000
Aluminum000	.000
Ammonia (as N)000	.000
Total suspended solids000	.000
Oil and grease000	.000
pH	(¹)	(¹)

¹Within the range of 7.0 to 10.0 at all times.

[49 FR 8796, Mar. 8, 1984, as amended at 49 FR 29794, July 24, 1984; 52 FR 25559, July 7, 1987]

§ 421.35 Pretreatment standards for existing sources.

Except as provided in 40 CFR 403.7 and 403.13, any existing source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for existing sources. The mass of wastewater pollutants in secondary aluminum process wastewater introduced into a POTW shall not exceed the following values:

(a) Subpart C—Scrap Drying Wet Air Pollution Control.

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum scrap dried	
Lead000	.000
Zinc000	.000
Ammonia (as N)000	.000

(b) Subpart C—Scrap Screening and Milling.

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum scrap screened and milled	
Lead000	.000
Zinc000	.000
Ammonia (as N)000	.000

(c) Subpart C—Dross Washing.

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of dross washed	
Lead	3.043	1.413
Zinc	11.090	4.565
Ammonia (as N)	1,449.000	636.000

(d) Subpart C—Demagging Wet Air Pollution Control.

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (lb/million lbs) of aluminum demagged	
Lead	0.216	0.100
Zinc	0.786	0.324
Ammonia (as N)	102.800	45.180

(e) Subpart C—Delacquering Wet Air Pollution Control.

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum delacquered	
Lead	0.093	0.043
Zinc	0.340	0.140
Ammonia (as N)	44.389	19.514
Total phenolics (4-AAP method) ¹	0.004

¹At the source.

(f) Subpart C—Direct Chill Casting Contact Cooling.

§ 421.36

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum cast	
Lead372	.173
Zinc	1.356	.558
Ammonia (as N)	177.200	77.800

(g) Subpart C—Ingot Conveyor Casting Contact Cooling (When Chlorine Demagging Wet Air Pollution Control is Not Practiced On-Site).

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (lb/million lbs) of aluminum cast	
Lead	0.019	0.009
Zinc	0.068	0.028
Ammonia (as N)	8.931	3.926

(h) Subpart C—Ingot Conveyor Casting Contact Cooling. (When Chlorine Demagging Wet Air Pollution Control is Practiced On Site.)

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum cast	
Lead000	.000
Zinc000	.000
Ammonia (as N)000	.000

(i) Subpart C—Stationary Casting Contact Cooling.

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum cast	
Lead000	.000
Zinc000	.000
Ammonia (as N)000	.000

(j) Subpart C—Shot Casting Contact Cooling.

40 CFR Ch. I (7–1–00 Edition)

PSES

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum cast	
Lead000	.000
Zinc000	.000
Ammonia (as N)000	.000

[49 FR 8796, Mar. 8, 1984, as amended at 49 FR 29794, July 24, 1984; 52 FR 25560, July 7, 1987]

§ 421.36 Pretreatment standards for new sources.

Except as provided in 40 CFR 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for new sources. The mass of wastewater pollutants introduced in secondary aluminum process wastewater into a POTW shall not exceed the following values:

(a) Subpart C—Scrap Drying Wet Air Pollution Control.

PSNS

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum scrap dried	
Lead000	.000
Zinc000	.000
Ammonia (as N)000	.000

(b) Subpart C—Scrap Screening and Milling.

PSNS

Pollutant or pollutant property	Maximum for any 1 day	Maximum for monthly average
	mg/kg (pounds per million pounds) of aluminum scrap screened and milled	
Lead000	.000
Zinc000	.000
Ammonia (as N)000	.000

(c) Subpart C—Dross Washing.